

## Minutes of Pre-Bid Meeting

Date: 19.07.2024

**Name of work: Supply, Installation, Testing & Commissioning of Firefighting System with addressable PA System at Majeedia Unani Hospital.**

As per schedule, a Pre-Bid Meeting for the above said work was held on 19.07.2024 in the office of the Executive Engineer. The following has been resolved as per the queries raised by the participating agencies.

1. If necessary, Civil work such as cutting/chiseling of walls, core-cutting, foundation of motor pump etc. will be part of the respective items. No extra payment will be made against any necessary civil works.
2. Size of Auto-glow Fire Signage will be as per the Norms of Delhi Fire Service Rule.
3. Item for dismantling of existing non-functional pipes & its fittings etc. & fire alarm panels also includes making goods of walls and removing/re-fixing of false ceiling and making good of false ceiling if got damaged during the dismantling/laying of pipes
4. The type of sprinkler is pendent type sprinkler.
5. Work shall be organized in such a manner which does not disturb the activities of the Hospital as well as Patients & staff of the Hospital.
6. The passage of the Hospital should be cleaned and shall not have any obstructions so that the movement of Patients & Hospital staff will not be disturbed.
7. All the bidders are advised to quote their rates considering the above points.

The above resolved queries will be a part of the tender and the tender will open on its Scheduled Date & Time i.e. 24.07.2024 at 03:30 PM.

Executive Engineer 'O'