

PRE-BID QUERY-ASNWERS

Ref.No. JH/Lab Furniture (Pharmacy)/02/2022

Date: 07.06.2022

Queries received in Pre-bid meeting held on 06.06.2022 at JH:

1. Rebate on EMD for MSME certifications.

No rebate on EMD for MSME certifications for vendors/bidders.

2. Extension of timeline for sample production/installation after qualifying Part A & B of Techno-commercial bid.

Based on the discussion with the competent authority, we extend the timeline from 10 days to 12 days for the sample installation.

3. Validity of Tender is mentioned as 180 days and 60 days, which one is to be considered?

Validity of the tender will be 60 days.

4. DLP & Warranty are mentioned as 1 year and 5 years respectively, so time for warranty will be considered after DLP or from date of handover?

DLP & Warranty both will be considered from the date of handover/completion of the project.

5. Quantities of Sink, storage modules, leg space, sockets to be mentioned in the furniture tables for providing better rates.

Quantities have been mentioned in their same BOQ, separately uploaded on the website with name "SPER_LAB_FURNITURE_BOQ_(Supplementary after Pre-bid)".

For electrical sockets, 1nos. 6A switch socket is to be considered for 1 metre length of furniture on average to calculate the requirements for lengths mentioned in the BOQ.

6. PP Ducting item quantity to be mentioned.

PP Ducting item quantity is added in the same BOQ, however it will be calculated as per actual measurement for the billing.

7. 3 Phase connection for exhaust fans for Fume hoods and connection between fume hoods and exhaust fans will be in client's scope or vendor's scope?

3 Phase connection for exhaust fans will be in client's scope and the connection between Fume Hoods and Exhaust Fans will be in vendor/ bidder's scope.

8. Which one to follow, BOQ or layout ?

BOQ items to be followed for the final quantities of storage modules, sinks, leg spaces, etc, however layouts are provided to have an understanding of which table is being used in which labs. Lab wise layouts were already provided with locations of sink marked in the layout for better understanding and working.